



# OFFICE OF CIVIL SURGEON PANCHKULA, HARYANA

Ph. No. 0172-2573907, Email: [dhs.cspkl@hry.nic.in](mailto:dhs.cspkl@hry.nic.in)  
Address: Civil Hospital, 5<sup>th</sup> Floor, C-Block, Sector 6, Panchkula  
Pincode: 134109

## HYGIENE CERTIFICATE

It is certified that inspection with regard to maintenance of Healthy Surroundings and Hygienic sanitisation condition of ARAVALI INTERNATIONAL SCHOOL, PANCHKULA was carried out on dated 01-10-2024. As per observation, proper health and sanitation condition have been found. The school has proper ventilation, facility for drinking water, garbage disposal and toilet facilities with hygienic conditions.

This office has no objection if school is granted recognition/affiliation.

This certificate is valid for one year from date of issue w.e.f 04-10-2024

  
Deputy Civil Surgeon  
Panchkula

No. HR/PKL/2024/27

Dated: 04<sup>th</sup> October 2024.

To

The Principal

ARAVALI INTERNATIONAL SCHOOL

DLF THE VALLEY, PANCHKULA

DISTRICT- PANCHKULA (HRY.)



# AquaCare

## ENVIRONMENTAL LABORATORY

(An ISO 9001:2015 CERTIFIED LABORATORY)

### TEST REPORT



TC-15060

Report/ULR No : TC150602500000247F  
 Sample Receipt Date : 20.03.2025  
 Analysis Date : 20.03.2025 to 26.03.2025  
 Date of Report Issue : 26.03.2025  
 Customer Ref No / Date : Nil

Sample Code No : AEL/03/25/247  
 Sample Description : Water  
 Sample Quantity : 1 litre  
 Sample Condition : Satisfactory  
 Sample Detail : **Marked as Drinking Water**

#### ISSUED TO: -

**Aravali International School**  
 DLF Valley Panchkula-134105

#### TEST RESULTS

PARAMETER TESTED			IS: 10500-2012 Drinking Water Specification (Second Revision)		
Sl No	PHYSICO-CHEMICAL	UNITS	RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Odour	-	Agreeable	Agreeable	IS:3025 (Part 05)-2018
2.	Turbidity	NTU	BDL(DL=0.1)	1	IS:3025 (Part 10)-2023
3.	pH value	-	7.05	6.5-8.5	IS:3025 (Part 11)-2022
4.	Total Dissolved Solids	mg/l	127	500	IS:3025 (Part 16)-2023
5.	Total Hardness as CaCO <sub>3</sub>	mg/l	32	200	IS:3025 (Part 21)-2009
6.	Calcium as Ca <sup>++</sup>	mg/l	6.4	75	IS:3025 (Part 40)-1991
7.	Magnesium as Mg <sup>++</sup>	mg/l	3.8	30	IS:3025 (Part 46)-2023
8.	Total Alkalinity as CaCO <sub>3</sub>	mg/l	44	200	IS:3025 (Part 23)-2023
9.	Chloride as Cl <sup>-</sup>	mg/l	43	250	IS:3025 (Part 32)-1988
10.	Free Residual Chlorine	mg/l	BDL(DL=0.2)	0.2	IS:3025 (Part 26)-2021
11.	Sulphate as SO <sub>4</sub> <sup>-</sup>	mg/l	5.5	200	IS:3025 (Part 24)-1986

BDL= Below Detection Limit. DL=Detection Limit,

#### Remarks: -

- 1) The above water sample **conforms** to IS: 10500-2012 Drinking Water Specification (Second Revision) with respect to the tests conducted.
- 2) The results relate to item tested.



\*End of Test Report\*

Page 1 of 1

Authorised Signatory  
**Dr. P. N. JHA**  
 Q.A. HEAD

**ADDRESS :** C-348, 3rd Floor, Ramphal Chowk, Sector-7, Dwarka, New Delhi-110077

**Phone :** 011-41608075, 8219717330, 9818785780

**E-mail :** aquacare.envlab@gmail.com **Website :** www.aquacarelab.com



# AquaCare

**ENVIRONMENTAL LABORATORY**  
(An ISO 9001:2015 CERTIFIED LABORATORY)

## TEST REPORT

Report No : AEL/2503/247  
Sample Receipt Date : 20.03.2025  
Analysis Date : 20.03.2025 to 26.03.2025  
Date of Report Issue : 26.03.2025  
Customer Ref No / Date : Nil

Sample Code No : AEL/03/25/247  
Sample Description : Water  
Sample Quantity : 1 litre  
Sample Condition : Satisfactory  
Sample Detail : **Marked as Drinking Water**

### ISSUED TO: -

**Aravali International School**  
DLF Valley Panchkula-134105

### TEST RESULTS

PARAMETER TESTED			IS: 10500-2012 Drinking Water Specification (Second Revision)		
SI No	PHYSICO-CHEMICAL	UNITS	RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Taste	-	Agreeable	Agreeable	IS:3025 (Part 08)-2023
2.	Fluoride as F <sup>-</sup>	mg/l	BDL(DL=0.10)	1.0	IS:3025 (Part 60)-2008
3.	Total Iron as Fe <sup>+</sup>	mg/l	0.12	1.0	IS:3025 (Part 53)-1988
4.	Nitrate as NO <sub>3</sub> <sup>-</sup>	mg/l	BDL(DL=1.0)	45	IS:3025 (Part 34)-2024

SI No	BACTERIOLOGICAL	RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Total Coliforms (MPN/100ml)	Not Detected	Not Detected	IS:1622 -1981
2.	Faecal Coliforms (MPN/100ml)	Not Detected	Not Detected	IS:1622 -1981
3.	<i>E. coli</i> in 100 ml of sample present/absent	Not Detected	Not Detected	IS:1622 -1981

BDL= Below Detection Limit. DL=Detection Limit,

### Remarks: -

- 1) The above water sample **conforms** to IS: 10500-2012 Drinking Water Specification (Second Revision) with respect to the test conducted.
- 2) The results relate to item tested.



\*End of Test Report\*

Page 1 of 1

Authorised Signatory  
**Dr. P. K. JHA**  
Q.A. HEAD

**ADDRESS :** C-348, 3rd Floor, Ramphal Chowk, Sector-7, Dwarka, New Delhi-110077

**Phone :** 011-41608075, 8219717330, 9818785780

**E-mail :** aquacare.envlab@gmail.com **Website :** www.aquacarelab.com